











TO BE PROVIDED BY OTHERS (Observation of all Standards, guidelines acc. to each specific country)

Clear access route into the building3,5 m x 3,5 m
access route must be obstruction free

Ⓔ Electric mains up to upper part of moving walk
Free cable ends 1500mm long

Ⓑ Lifting points by others
loading per point 50 kN

Ⓩ Intermediate support after erection of the moving walk by others
Additionally 10% of the intermediate-support-forces have to be concidered as horizontal forces

A railing reaching right to the moving walk balustrades must be mounted according to EN 115-1 2008 A2.7. This railing must be designed to prevent people from falling down the balustrades when they let themselves being dragged by the handrail. The entry to the moving walk handrail must be prevented. Barrier plates do not perform the function of a protective railing! See detail cross section!



© (THYSSENKRUPP FAHRTREPPEN GMBH 2016)

ThyssenKrupp Fahrtreppen

Cross section



Support



Tolerance which have to be kept by others	Deviations in mm for distance at the measuring points					
	to 4m	10m	25m	50m	100m
	± 5	± 10	± 15	± 20	± 30

	Modifications		
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			

orinoco xtra — 4 EK - 800mm 12°

	Date	Name
Drawn	16.08.2016	Wildow

moving walk (slimline, indoor)
UTK / OTK

Installation of an moving walk

E12060561-00

Scale 1:50 1:10

thyssenkrupp